



## Propane

| Property                                    | Unit | Test                | Value          |
|---|------|---------------------|----------------|
| SP.GR.@60°F                                 |      | ASTM D2598          | to be reported |
| Propane Content(Vol%)                       |      | ASTM D2163          | 96 min         |
| Ethane Content                              |      | ASTM D2163          | 2 max          |
| Vap.Pressure@100F( psig)                    |      | ASTM D1267 or D2598 | 200 max        |
| Volatile residue: C4 & heavier (vol %)      |      | ASTM D2163(1)       | 2.5 max        |
| Residual Matter: Resid.on evap.of 100ml(ml) |      | ASTM D2158          | 0.05 max       |
| Residual Matter: oil stain observation(ml)  |      | ASTM D2158          | Pass(2)        |
| Corrosion Copper Strip                      |      | ASTM D1838 or D5453 | No.1 Strip     |
| Sulphur Content (WT%)                       |      | ASTM D1266          | 0.04 max       |
| Hydrogen Sulphide                           |      | ASTM D2420 or IP103 | Negative       |
| Moisture Content                            |      | ASTM D2713 or D1744 | Pass           |