

Fuel Oil

Property	Unit	Test	Value
		ASTM D 4052	0.9798
API		ASTM D 1298	12.92
SULPHUR CONTENT (Total)	wt%	ASTM D 4294	2.85
BASE SEDIMENT & WATER	vol%	ASTM D 1796	0.05
WATER CONTENT	vol%	ASTM D 4006	<0.05
SALT CONTENT	P.T.B	ASTM D 3230	10
F		ASTM D 93	164
"	mm ² /Sec	ASTM D 445	907
"	mm ² /Sec	ASTM D 445	376
POUR POINT		ASTM D 5853	3
ASH CONTENT	Wt.%	ASTM D 482	0.03
ASPHALTENES	wt%	IP 143	5.4
Wt.%			
WAX CONTENT	wt%	BP 237	7.5
DROP MELTING POINT OF WAX		IP 133	72
CARBON RESIDUE CONRADSON	wt%	ASTM D 189	13.4
ACIDITY , TOTAL	mgKOH/gr	UOP 565	0.08
CALORIFIC VALUE	Kcal/Kg	CALCULATED	10141
NICKEL CONTENT	PPm	ASTM D 5863	39
PPm	PPm	ASTM D 5863	137
PPm	PPm	ASTM D 5863	<1
PPm	PPm	ASTM D 5863	<1
PPm	PPm	ASTM D 5863	13

